



CERTIFICATE OF CONFORMITY

SAI Global hereby grants:

AVK Australia Pty Ltd

ABN 11081236777

559A Grand Junction Road, WINGFIELD, SA 5013, Australia

WaterMark Certificate of Conformity – Level 1

Evaluated to:

AS 2638.2-2006 - Gate valves for waterworks purposes - Resilient seated

“the WaterMark Licensee” the right to use or arrange the use of the WATERMARK as shown below only in respect of the goods described and detailed on the product schedule identified on www.saiglobal.com which are produced by the WaterMark Licensee or on behalf of the WaterMark Licensee* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the WATERMARK and the Terms and Conditions for certification. The WaterMark Licensee covenants to comply with all the Rules and Terms and Conditions

Certificate No: WMKA02420

Issued : 7 November 2011

Expires : 6 November 2016

Originally Certified : 7 November 2011

Current Certification : 7 November 2011

Duncan Lilley
Global Head – Assurance Services

Alex Ezrakhovich
General Manager – Certification Services



WaterMark



WWW.JAS-ANZ.ORG/REGISTER

* For details of manufacture, refer to the licensee

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) (“SAI Global”) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

 **SAI GLOBAL**
INFORM. INSPIRE. IMPROVE.

SCHEDULE TO CERTIFICATE OF CONFORMITY

SAI Global hereby grants :

AVK Australia Pty Ltd

559A Grand Junction Road, WINGFIELD, SA 5013, Australia

WaterMark Certificate of Conformity – Level 1

Evaluated to:

AS 2638.2-2006 - Gate valves for waterworks purposes - Resilient seated

Model identification of the goods on which the WATERMARK may be used:

Model Identification	Model Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operation Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
55	RSGV	DN500 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 500	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
55	RSGV	DN450 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 450	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
55	RSGV	DN600 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 600	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
55/80	RSGV	DN600 Resilient Seated Gate Valve with DN150 Bypass valve	Resilient Seated Gate Valve	DN 600	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011

Certificate No: WMKA02420

Issued Date: 7 November 2011

This schedule supersedes all previously issued schedules



* For details of manufacture, refer to the licensee

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

SCHEDULE TO CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operation Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57	RSGV	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Socket	1 Nov 2011
57	RSGV	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Socket	1 Nov 2011
57	RSGV	DN80 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Spigot x Spigot	1 Nov 2011

Certificate No: WMKA02420

Issued Date: 7 November 2011

This schedule supersedes all previously issued schedules



Registered by:

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

SCHEDULE TO CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operation Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57	RSGV	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Spigot x Spigot	1 Nov 2011
57	RSGV	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Spigot x Spigot	1 Nov 2011
57	RSGV	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011

Certificate No: WMKA02420

Issued Date: 7 November 2011

This schedule supersedes all previously issued schedules



Registered by:

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

SCHEDULE TO CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operation Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57	RSGV	DN80 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Socket x Socket	1 Nov 2011
57	RSGV	DN400 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 400	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57	RSGV	DN375 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 375	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel 3/Gearbox	Option of CC or ACC	Flange x Flange	1 Nov 2011
57/55	RSGV	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011
57/55	RSGV	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011
57/55	RSGV	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011

Certificate No: WMKA02420

Issued Date: 7 November 2011

This schedule supersedes all previously issued schedules



Registered by:

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

SCHEDULE TO CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operation Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57/55	RSGV	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011
57/55	RSGV	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011
57/55	RSGV	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011
57/55	RSGV	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Socket x Socket	1 Nov 2011
57/65	RSGV	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Spigot x Spigot	1 Nov 2011
57/75	RSGV	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Socket	1 Nov 2011
57/90	RSGV	DN150 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 150	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011
57/90	RSGV	DN225 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 225	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011

Certificate No: WMKA02420

Issued Date: 7 November 2011

This schedule supersedes all previously issued schedules



Registered by:

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.

SCHEDULE TO CERTIFICATE OF CONFORMITY

Model Identification	Model Name	Product Description	Product Type	Nominal Size (DN)	Valve Class (Allowable Operating Pressure)	Maximum Operating Temperature (°C)	Material Designation	Valve Coating Material	Valve Operation Method	Valve Direction of Closure	End Connection Designation	Date Endorsed
57/90	RSGV	DN200 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 200	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011
57/90	RSGV	DN300 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 300	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011
57/90	RSGV	DN080 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 80	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011
57/90	RSGV	DN250 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 250	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011
5790	RSGV	DN100 Resilient Seated Gate Valve	Resilient Seated Gate Valve	DN 100	16	40°C	Ductile Cast Iron	Polymeric in accordance with AS 4158 - Akzo Nobel Resicoat R-4ES 30 HJF38A	Option of 1/Stemcap 2/Handwheel	Option of CC or ACC	Flange x Flange	1 Nov 2011

End of Record

Certificate No: WMKA02420

Issued Date: 7 November 2011

This schedule supersedes all previously issued schedules

Registered by:



The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to www.saiglobal.com for the list of product models.